



See online technical sheet

/ ENSPAC1050

Earthing device using insulating rope for bare HV overhead line
(Set for 1 conductor)



/ Standards

- CEI 61230

/ Use

This clamp is placed and unhooked from the ground using an insulating rope passed over the conductor. The clamp is raised onto the conductor by pulling on the 1st rope. The clamp is unhooked by pulling on the 2nd rope. The rope can be passed over the conductor using an insulating pole fitted with the quick-hooking system.

/ Areas of activity

 Transport

/ Technical specifications

- Product kind : Earthing equipment/kits
- Operating voltage (V) : HTB

Product reference	Cross-section (mm ²)	Floor cable length (m)	Measurement	Weight (kg)
ENSPAC1050A	95	14	HMALT: 600x250x200mm / H701: 1300x120x120mm	21,5
ENSPAC1060B01	95.	14.	HMALT: 600x250x200mm / H701: 1300x120x120mm.	3 x 21,5